


\* DMS METER (OPTIONAL) APPLICABLE IN FARMINGTON HILLS AND COMMERCE TOWNSHIP.

\*\* LAWN SPRINKLER SYSTEMS REQUIRE AN APPROVED BACKFLOW DEVICE TO BE TESTED AT INITIAL INSTALLATION AND EVERY 1 - 5 YEARS THERE AFTER AS REQUIRED BY W.R.C.

\*\*\* WATER TAPS CANNOT BE MADE ON PRIVATE PROPERTY (OUTSIDE OF EASEMENTS OR OUTSIDE OF ROAD RIGHT-OF-WAY). THE W.R.C. DOES NOT INFRINGE ON THE COMMON GROUNDS OR PRIVATE PROPERTY OF CONDOMINIUM COMPLEXES.

\*\*\*\* A SEPARATE FIRE SERVICE TAP IS REQUIRED FOR BUILDINGS WITH FIRE PROTECTION. DOMESTIC SERVICE TAP CANNOT BE MADE ON THE FIRE LINE.

## TYPICAL WATER SERVICE LAYOUT

REVISION BLOCK				<div><b>WRC</b> WATER RESOURCES COMMISSIONER <i>Jim Nash</i></div>	WATER SERVICE DETAIL			
Parcel Base / Source Date: N/A					<div>ONE PUBLIC WORKS DRIVE, BLDG 95 WEST WATERFORD, MICHIGAN 48328-1907</div> <div>ORIG. DATE: 6-25-02 SCALE: N.T.S.</div> <div>SHEET: 1 of 1</div>			
Rev. No.:	Rev. By:	Rev. Date:	Description:					
1	Iz	03/24/05	REVISED DETAILS AND NOTES					
2	Iz	08/21/07	REVISED SERVICE NOTES					
3	DS	09/17/09	REVISED SERVICE NOTES					
4	DS	01/03/13	REVISED SERVICE NOTES					