



* DMS METER (OPTIONAL) APPLICABLE IN COMMERCE TOWNSHIP, FARMINGTON HILLS, ORCHARD LAKE, OXFORD TOWNSHIP (NON-RESIDENTIAL ONLY), PONTIAC, SYLVAN LAKE, WALLED LAKE, AND WOLVERINE LAKE.

** LAWN SPRINKLER SYSTEMS REQUIRE AN ASSE APPROVED, PROPERLY INSTALLED BACKFLOW PREVENTION ASSEMBLY. THESE ASSEMBLIES ARE REQUIRED TO BE TESTED UPON INSTALLATION, RELOCATION AND/OR REPAIR AND AT A MINIMUM OF ONCE EVERY 1 - 5 YEARS BY A LICENSED PLUMBER WITH AN AMERICAN SOCIETY OF SANITARY ENGINEERING (ASSE) 5110 CERTIFICATION AS REQUIRED BY WRC.

*** WATER TAPS CANNOT BE MADE ON PRIVATE PROPERTY (OUTSIDE OF EASEMENTS OR OUTSIDE OF ROAD RIGHT-OF-WAY). THE W.R.C. DOES NOT INFRINGE ON THE COMMON GROUNDS OR PRIVATE PROPERTY OF CONDOMINIUM COMPLEXES.

**** A SEPARATE FIRE SERVICE TAP IS REQUIRED FOR BUILDINGS WITH FIRE PROTECTION. DOMESTIC SERVICE TAP CANNOT BE MADE ON THE FIRE LINE.

TYPICAL WATER SERVICE LAYOUT

| REVISION BLOCK | | | | <div>  WATER RESOURCES COMMISSIONER <i>Jim Nash</i> </div> <div> WATER SERVICE DETAIL </div> | | | |
|----------------|----------|------------|-----------------------|--|-------------|---------|--------|
| Rev. No.: | Rev. By: | Rev. Date: | Description: | | | | |
| 1 | Iz | 08/21/07 | REVISED SERVICE NOTES | <div> ONE PUBLIC WORKS DRIVE, BLDG 95 WEST WATERFORD, MICHIGAN 48328-1907 </div> | ORIG. DATE: | 6-25-02 | SHEET: |
| 2 | DS | 09/17/09 | REVISED SERVICE NOTES | | SCALE: | N.T.S. | 1 of 1 |
| 3 | DS | 01/03/13 | REVISED SERVICE NOTES | | | | |
| 4 | KB | 01/16/25 | REVISED SERVICE NOTES | | | | |