

## **AIR GAP LOG**

Equipment	Date	Checked By (Initials)	Corrective Actions

5-402.11: A direct connection may not exist between the sewage system and a drain originating from equipment in which food, portable equipment, or utensils are placed.

5-202.13: An air gap between the water supply inlet and the flood level rim of the plumbing fixture, equipment, or nonfood equipment shall be at least one inch.