


- VALVE BOX (1 REQ'D)
TO BE PLACED OVER
EACH VALVE
COVER LABELED "SEWER"

1. CLEAN-OUT MANHOLE TO BE 6 FT. DIA STRUCTURE (MIN.)
2. SEE TYPICAL MH DETAIL FOR ADDITIONAL DETAILS
3. ALL FORCEMAIN COMPONENTS SHALL BE DUCTILE IRON.
4. PIPE TRANSITIONS SHALL BE MADE MAX. 20' & MIN. 5' OUTSIDE OF MANHOLE.



12" AND LARGER FORCEMAIN FLUSHING ASSEMBLY

NO SCALE

REVISION BLOCK				 WATER RESOURCES COMMISSIONER <i>Jim Nash</i>	FORCEMAIN FLUSHING ASSEMBLY			
Parcel Base / Source Date:								
Rev. No.:	Rev. By:	Rev. Date:	Description:		ONE PUBLIC WORKS DRIVE, BLDG 95 WEST WATERFORD, MICHIGAN 48328-1907 ORIG. DATE: SCALE: SHEET: NONE 1 of 1			
1	Iz	06/18/09	WRC APPROVED NEW DETAIL					
2								
3								
4								