



- AMERICAN SOCIETY OF SANITARY ENGINEERING (ASSE) APPROVED PRESSURE VACUUM BREAKERS MUST BE PROPERLY INSTALLED NOT LESS THAN 12 INCHES ABOVE ALL DOWNSTREAM PIPING AND OUTLETS.
- PIPING ELEVATION OR CHEMICAL ADDITIONS REQUIRE THE PROPER INSTALLATION OF AN ASSE APPROVED REDUCED PRESSURE BACKFLOW PREVENTER.
- BACKFLOW PREVENTION ASSEMBLIES REQUIRE TESTING UPON INSTALLATION, RELOCATION AND/OR REPAIR BY A LICENSED PLUMBER WITH AN ASSE 5110 CERTIFICATION.
- METER AND BACKFLOW PREVENTER TO BE PLACED IN AN AREA NOT PRONE TO FLOODING
- CUSTOMER MUST INSTALL METER AND BACKFLOW PREVENTER. CUSTOMER IS RESPONSIBLE FOR METER & BACKFLOW PREVENTER. IT IS RECOMMENDED THAT CUSTOMER PLACE METER & BACKFLOW PREVENTER INSIDE CABINET (HOT BOX) PROVIDED W.R.C. HAS ACCESS.
- BLOW-OFF RISERS ON WATER SERVICE LINES ARE NOT ALLOWED.
- SYSTEM NEEDS TO BE PUMPED OUT FROM METER BACK TO STOP (CURB) BOX.
- IT IS THE OWNER'S RESPONSIBILITY (NOT W.R.C.) TO REMOVE METER DURING WINTER MONTHS TO AVOID DAMAGE TO THE METER.

WATER TAP

- ALL WATER TAPS 2" AND SMALLER ARE MADE BY W.R.C.
- WATER SPRINKLER TAPS ARE SHORT TAPS ONLY. UNLESS APPROVED BY W.R.C.
- ALL STOP (CURB) BOXES WILL BE INSTALLED WITHIN 10' OF THE WATER MAIN. UNLESS APPROVED BY W.R.C.
- THE CUSTOMER IS RESPONSIBLE FOR ALL CLEANUP AND RESTORATION RESULTING FROM A SERVICE LINE INSTALLATION FOR IRRIGATION PURPOSES.

PROFILE

LAWN SPRINKLER RISER DETAIL

NOT TO SCALE

